

# ***Annual Drinking Water Quality Report***

## **2024**

### **TOWN OF CONKLIN WATER DEPARTMENT**

1271 Conklin Road; Conklin, New York  
Public Water Supply I.D. Number NY0301660

#### **INTRODUCTION**

We're very pleased to provide you with this year's Annual Quality Water Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is, and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is groundwater, which is withdrawn from the aquifer via two wells. The primary well (Well #6) is located on Terrace Drive. The second well (Well #5) is also located at the same facility. Both wells are treated at the Well #5 & #6 treatment plant on Terrace Drive. Treatment of the Town of Conklin water consists of disinfection with liquid chlorine, fluoridation, and the addition of an approved sequestering agent/pipe coating chemical called Aqua Mag.

A Source Water Assessment has been completed for our water system. A summary of this assessment has been completed by the Broome County Health Department and is attached to this report. A source water protection plan is available from our office that provides more information such as potential sources of contamination.

The Town of Conklin Water Department is pleased to report that our drinking water substantially meets federal and state requirements. The enclosed report shows our water quality and what it means. We want our valued customers to be informed about their water utility. If you have any questions about this report or concerning your water utility, please contact the Water Department at (607) 775-4584. If you want to learn more, please attend any of the Town Board's regularly scheduled meetings. They are held on the second Tuesday of every month, 6:00 p.m., at the Conklin Town Hall located at 1271 Conklin Road; Conklin, New York.

#### **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, lead and copper, volatile organic compounds, synthetic organic compounds, disinfection byproducts,

and emerging organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. Also, you may notice that some of our samples were collected in January 2024. This was due to a sample collection scheduling problem with the laboratory. These sample results are for the 2024 sampling year.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Broome County Health Department (607-778-2887).

## **WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no violations, but we have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements.

Although our lead levels are well below the Action Level, we are required to present the following information on lead in drinking water:

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Town of Conklin is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact the Town of Conklin Water Department at 607-775-4584. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

## **EMERGING ORGANIC CONTAMINANTS**

**Perfluorooctanoic acid (PFOA), Perfluorooctansulfonic acid (PFOS), and 1,4 Dioxane (1,4-D)**  
PFOA, PFOS, and 1,4-D are relatively ubiquitous in the environment due to their historical widespread use and persistence. The New York State Health Department has instituted regulations requiring water systems to test for these contaminants.

PFOA and PFOS have been used in a variety of consumer and industrial products as surface coatings and/or protectants because of their nonstick properties. Research indicates that these compounds bioaccumulate in various organisms, including fish and humans.

1,4-D has been largely used as a solvent stabilizer for chemical processing but can also be found as a purifying agent in the manufacturing of pharmaceuticals as well as a contaminant in ethoxylated surfactants commonly used in consumer cosmetics, detergents, and shampoos. Research indicates that this chemical does not bioaccumulate in the food chain.

We are pleased to inform you that we did not detect any of these compounds in our drinking water.

## **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2024, our system was in substantial compliance with applicable State drinking water operating, monitoring and reporting requirements.

## **INFORMATION ON LEAD SERVICE LINE INVENTORY**

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by visiting our website at [www.townofconklin.org/](http://www.townofconklin.org/)

## **INFORMATION ON FLUORIDE ADDITION**

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. To ensure that the fluoride supplement in your water provides optimal dental protection, we monitor fluoride levels on a daily basis to make sure fluoride is maintained at a target level of 0.7 mg/l. During 2024, monitoring showed that fluoride levels in your water were within 0.2 mg/l of the target level for greater than 90% of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

## **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water substantially met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

Saving water saves energy and some of the costs associated with both of these necessities of life;

Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and

Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.

Turn off the tap when brushing your teeth.

Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day.

Fix it and you can save almost 6,000 gallons per year.

Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

## **CONCLUSION**

We at the Town of Conklin Water Department works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office at (607) 775-4584 if you have questions regarding this document or the Town of Conklin Water System in general.

# TABLE OF DETECTED CONTAMINANTS - CONKLIN

Contaminant	Violation Yes/No	Sample Location	Date of Sample	Level Detected (range)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
Barium	No	Wells 5 & 6 Entry Point	5/20/24	0.0508	mg/l	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Lead <sup>2</sup>	No	Distribution	9/28/23	1.0 (ND-1.0)	ug/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits.
Copper <sup>2</sup>	No	Distribution	9/28/23	0.937 (0.192-1.07)	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Nitrate (as Nitrogen)	No	Wells 5 & 6 Entry Point	1/18/24	1.51	mg/l	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Fluoride	No	Wells 5 & 6 Entry Point	1/18/24	1.54	mg/l	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Sodium <sup>3</sup>	No	Wells 5 & 6 Entry Point	5/20/24	37.2	mg/l	N/A	See Health Effects	Naturally occurring; Road salt; Water softeners; Animal waste.

## Disinfection Byproducts

Total Trihalomethanes <sup>4</sup>	No	Distribution	9/28/23	38.7	ug/l	N/A	80	By-product of drinking water chlorination.
------------------------------------	----	--------------	---------	------	------	-----	----	--

## Radiological Contaminants

Radium-226	No	Wells 5 & 6 Entry Point	8/22/22	0.0746	pCi/L	0	5	Erosion of natural deposits.
Radium-226	No	Wells 5 & 6 Entry Point	8/22/22	0.824	pCi/L	0	5	Erosion of natural deposits.

## Notes:

2	The level presented represents the 90th percentile of the sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead/copper values detected at your water system.
3	Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.
4	This level represents the total levels of the following contaminants: chloroform, bromodichloromethane, dibromochloromethane, bromoform.

## Definitions:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Milligrams per liter (mg/l):** Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Micrograms per liter (ug/l):** Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**Picocuries per liter (pCi/L):** A measure of the radioactivity in water.

Conklin Water Department  
NY0301660  
AWQR Source Water Assessment Summary

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells, called the well sensitivity. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section “Are there contaminants in our drinking water?” for a list of the contaminants that have been detected. While nitrate and other inorganic contaminants were detected in our water, it should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence of contaminants does not necessarily indicate that the water poses a health risk.

As mentioned before, our water is derived from two drilled primary wells. The sensitivity of both wells is rated as high since they draw water from an unconfined productive aquifer that may not provide adequate protection from potential contamination. The source water assessment has rated these wells as having a medium-high susceptibility to microbial contaminants, such as enteric bacteria, enteric viruses and protozoa. These ratings are due primarily to the presence of unsewered residential areas in the vicinity of the wells. The assessment has also rated the wells as having a low to medium-high (specifically petroleum products due to the presence of tractor trailers in the vicinity) susceptibility to chemical contaminants as noted in the table below. A low susceptibility is warranted when no known source of a particular contaminant is identified in the capture zone of the well. While the source water assessment rates our wells as being moderately susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State’s drinking water standards for microbial contamination.

SUSCEPTIBILITY TABLE		
CONTAMINANT	Well #5	Well #6
Cations/Anions	Low	Low
Enteric Bacteria	Medium-High	Medium-High
Enteric Viruses	Medium-High	Medium-High
Halogenated Solvents	Low	Low
Herbicides/Pesticides	Low	Low
Metals	Low	Low
Nitrate	Medium-High	Medium-High
Other Industrial Organics	Low	Low
Petroleum Products	Medium-High	Medium-High
Protozoa	Medium-High	Medium-High

The Town of Conklin currently has an active wellhead and watershed protection plan in place to ensure drinking water safety and the source water assessment is another tool that can help direct further refinements to the plan. County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs.

# *Annual Drinking Water Quality Report* **2024**

## **TOWN OF CONKLIN WATER DISTRICT #6**

1271 Conklin Road; Conklin, New York  
Public Water Supply I.D. Number NY0330058

### **INTRODUCTION**

We're very pleased to provide you with this year's Annual Quality Water Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is, and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is groundwater supplied by the Town of Kirkwood which is piped under the Susquehanna River to supply Conklin Water District #6. The 2024 Annual Water Quality Report for the Town of Kirkwood is attached.

If you have any questions about this report or concerning your water utility, please contact the Water Department at (607) 775-4584. If you want to learn more, please attend any of the Town Board's regularly scheduled meetings. They are held on the second Tuesday of every month, 6:00 p.m., at the Conklin Town Hall located at 1271 Conklin Road; Conklin, New York.

### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

As the State regulations require, we routinely test your drinking water for contaminants. These contaminants include total coliform and disinfection byproducts. The following compounds were detected in your drinking water:

Nitrate, inorganic contaminants, were collected on 5/29/24 and detected at .38 mg/l which is below the Maximum Contaminant Level of 10 mg/l.

Total Trihalomethanes, byproducts of chlorine disinfection, were collected on 9/17/2024 and detected at 16.29 ug/l which is below the Maximum Contaminant Level of 80 ug/l.

Trichloroethylene, organic contaminants, were collected on 9/16/24 and detected at .66 ug/l which is below the Maximum Contaminant Level of 5 ug/l.

### **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2024, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

### **CONCLUSION**

We at the Town of Conklin Water Department work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our drinking water. Please call our office at (607) 775-4584 if you have questions regarding this document or the Town of Conklin Water System in general.

## KIRKWOOD WATER - TABLE OF DETECTED CONTAMINANTS 2024

[illegible]